DECLARATION OF PERFORMANCE

in accordance with Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020

ASTRO X SERIES®

CE PIPE WRAP UL **0843-CPR-1394**

1. Unique identification code of product-type:

XSPWU

2. Intended use/es:

For fire compartmentation and / or fire protection or performance, 0843-UKTA-24/0045 and EAD 350454-00-1104.

3. Manufacturer:

Astroflame Fireseals Ltd, Unit 8, The I O Centre, Stephenson Road, Segensworth, Fareham Hampshire, PO15 5RU

4. Not applicable

5. System/s of AVCP: AVCP System 1

6b. European Assessment Document: EAD 350454-00-1104 - September 2017
UK Technical Assessment: 0843-UKTA-24/0045
Technical Assessment Body: BBA International (UK) Ltd
Notified Body/ies: 0843

7. Declared performance:

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class E according to EN13051-1
Resistance to Fire	Resistance to fire performance & field of application in accordance with EN13051-2 See 0843-UKTA-24/0045 Annex A
Dangerous Substances	0843-UKTA-24/0045 Section 3
Service & Durability	Type: X Intended for use in conditions exposed to weathering in accordance with EOTA technical document 024
Other	Not applicable/No performance determined

8. Appropriate Technical Documentation and/or Specific Technical Documentation: 0843-UKTA-24/0045
Link to the online copy of the declaration of performance: www.astroflame.com

Signed on the behalf of the manufacturer by:

P.Kieser - Managing Director 15/11/2024 **(Place of signature : Segensworth Fareham)** **C.Davis - Technical Managing** 15/11/2024

coming soon